



# Certificate of Continued Compliance 202350057/AA/00



Issued	15-02-2021	Replaces	
Expiry date	14-02-2025	Page	1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description:	Q20 Capture wall mount quad PIR
Trademark:	Capture
Type designation:	AKCA0000
Serial No:	N/A
Hardware / Software:	AKCA0000 / FIR0164-2.3
Variants:	See Annex 3

Placed on the market under the name or trademark of:

Name of the manufacturer:	Texecom Ltd.
Address:	St. Crispin Way
City:	BB4 4PW HASLINGDEN
Country:	United Kingdom of Great Britain and Northern Ireland

This certificate is granted to:

Name of the certificate holder:	Texecom Ltd.
Address:	St. Crispin Way
City:	BB4 4PW HASLINGDEN
Country:	United Kingdom of Great Britain and Northern Ireland

Ron Scheepers  
Managing director

*This certificate has THREE Annexes.*

# CERTIFICATE

Telefication B.V.  
Kiwa FSS Products  
Wilmersdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



**Remarks and observations**

The following conditions are applicable:

Security grade: 2

Environmental class: II

Equipment class: Fixed

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.

Factory location:

Texecom Ltd

St Crispin Way

BB4 4PW, Haslingden

United Kingdom

Product inspection location:

JCL Logistics Benelux B.V.

Everdenberg 14

Oosterhout

The Netherland

**Documentation lodged for this Certificate of Continued Compliance**

Test Reports:

- Telefication B.V.: 200300038-001-Ver. 1.00, 25 January 2021
- Telefication B.V.: 200300047-001-Ver. 1.00, 25 January 2021
- Element Materials Technology: TSR-TRA-045950-35-00A\_1\_\_Emissions \_ Susceptibility Test report for Capture P12, P15 Q15 and CQ\_\_Doc\_, 25 July 2019
- Element Materials Technology: TSR-TRA-045950-35-13A\_1\_\_Report on EMC Testing on Capture A20 with New Pyro\_\_Doc\_, 14 January 2021

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

**Technical Standards and Specifications**

The product shows no non-compliances with:

EN 50131-2-2 November, 2017

**Applied Standards**

EN 50130-5 June, 2011  
EN 50130-4+A1 October, 2014  
EN 50131-1+A1+A2 May, 2017

**The product as described in this certificate includes the following type designations**

- Product description: Q20 Capture wall mount quad PIR  
- Trademark: Capture  
- Type designation: AKCA0000  
- Hardware version: AKCA0000  
- Software version: FIR0164-2.3  
- Serial number: N/A

- Product description: CQ Capture Ceiling mount PIR  
- Trademark: Capture  
- Type designation: AKFA0000  
- Hardware version: AKFA0000  
- Software version: FIR0165-2.3  
- Serial number: N/A