




Member of



# Certificate of Conformity with European standards for Components and Systems

Number of Certificate	Valid from dd-mm-yyyy	Valid until dd-mm-yyyy
EN-ST-000059	29-11-2019	28-11-2023

Subject matter of Certificate:

**Power supply equipment grade 3  
SPCP 333.300**

Owner of Certificate:

**Vanderbilt International (IRL) Ltd.  
Clonshaugh Business & Technology Park  
IE-D17 KV84 DUBLIN 17**

Basis for certification:

**SES-EMA-RL-T2:2010-08  
EN 50131-6:2017**

Use, the product disposes of the following parameters:

**Intrusion and hold-up systems, Grade 3**

The tests were carried out at VdS Schadenverhütung GmbH  
and the results are documented in test report:

**101517-101519 dated 28-11-2011, 131653 dated 26-11-2013**

VdS Schadenverhütung GmbH  
Certification Body  
Amsterdamer Str. 174  
D-50735 Köln

A company of the German  
Insurance Association (GDV)  
accredited by DAkkS as certifica-  
tion body for fire protection and  
security products



To guarantee the permanent quality of products a regular surveillance of the manufacturing process is performed.

This certificate comprises 4 pages and shall only be reproduced without any modifications and including all enclosures.

Date: 29-05-2019

Managing director

Head of certification body



To Certificate No.: EN-ST-000059

Date : 29-05-2019

The approved component/system comprises the following parts:

Description of component	Type	Applicant's Registration No.	Approval number of component (only complete for system approval)
<p>Power supply unit (Type A) with build-in X-Bus expander SPCE652.100, mounted in a hinged metal enclosure.</p> <ul style="list-style-type: none"><li>- Battery capacity: 17 Ah / 12 V</li><li>- Auxiliary power: 2x 750 mA</li><li>- Output voltage: 11-14 V</li><li>- Hardware Revision: A3</li><li>- Firmware Revision: V10</li><li>- EN Grade 3</li></ul>	SPCP333.300	V54545-C101-A100	

To Certificate No.: EN-ST-000059

Date : 29-05-2019

The approved component/system is described as follows:

Type of document	Manufacturer's identification	Date	Number of Pages
Installation Manual: - SPCP332/333 Drawings: - Hinged metal enclosure Technical Documents: - Circuit diagram - Bill of Material - Face plan - Layout	A6V10216041  E-CA128912  E-PC139515e V54545-C101-A100 E-PC139515e E-PC139515e	01.10.2015  18.02.2015  29.04.2019 29.04.2019 30.05.2019 30.05.2019	18  14  8 5 1 7
(Technical documents of the build-in expander SPCE652.100 are listed in the certificate EN-ST-000064).			



**Enclosure 3**

**Sheet 1**

To Certificate No.: EN-ST-000059

Date : 29-05-2019

Instructions for the application of the approval component/system (see enclosure 1):

1. The device is suitable for use in intruder alarm systems according to EN 50131-1:2009.
2. The device complies with Environmental Class II of EN 50130-5:1998.
3. The device complies with EN 50130-4:2011 + A1:2014.