




Member of



# Certificate of Conformity with European standards for Components and Systems

Number of Certificate	Valid from dd-mm-yyyy	Valid until dd-mm-yyyy
EN-ST-000060	29-11-2015	13-06-2018

Subject matter of Certificate:

**Power supply equipment grad 2  
SPCP 332.300**

Owner of Certificate:

**Vanderbilt International (IRL) Ltd.  
Clonshaugh Business & Technology Park  
IE- DUBLIN 17  
IRELAND**

Basis for certification:

**EN 50131-6:2008  
SES-EMA-RL-T2:2010-08**

Use, the product disposes of the following parameters:

**Intrusion and hold-up systems, Grade 2**

**VdS Schadenverhütung GmbH**  
Zertifizierungsstelle  
Amsterdamer Str. 174  
D-50735 Köln

a company of the Gesamtverband  
der Deutschen Versicherungs-  
wirtschaft e.V. (GDV)

VdS Laboratories are accredited  
by DAkkS according to  
DIN EN ISO/IEC 17025  
as a test laboratory.  
The accreditation is valid  
for the test methods listed  
in the accreditation document

The tests were carried out at VdS Schadenverhütung GmbH  
and the results are documented in **test report:**

**101517-101519 dated 28-11-2011, 131653 dated 26-11-2013**

To guarantee the permanent quality of products a regular surveillance of the manufacturing process is performed.

This certificate comprises 4 pages and shall only be reproduced without any modifications and including all enclosures.



Date: 10-06-2015

Managing director

Head of certification body

To Certificate No.: EN-ST-000060

Date : 10-06-2015

The approved component/system comprises the following parts:

Description of component	Type	Applicant's Registration No.	Approval number of component (only complete for system approval)
<p>Power supply unit (Type A) with build-in X-Bus expander SPCE652.100, mounted in a small metal enclosure.</p> <ul style="list-style-type: none"> <li>- Battery capacity: 7 Ah / 12 V</li> <li>- Auxiliary power: 2x 750 mA</li> <li>- Output voltage: 11-14 V</li> <li>- Hardware Revision: A1</li> <li>- Firmware Revision: V10</li> <li>- EN Grade 2</li> </ul>	<p>SPCP332.300</p>	<p>S54545-C102-A100</p>	

**Enclosure 2**

Sheet 1

To Certificate No.: EN-ST-000060

Date : 10-06-2015

The approved component/system is described as follows:

Type of document	Manufacturer's identification	Date	Number of Pages
Installation Manual: - SPCP332/333	A6V10216041	08.02.2013	17
Drawings: - Small metal enclosure	E-PC138612	09.11.2011	8
Technical Documents: - Circuit diagram	E-PC139514	25.11.2010	14
- Bill of Material	S54545-C102-A100	01.10.2013	5
- Face plan	E-PC139514	17.05.2011	1
- Layout	E-PC139514	17.05.2011	7
(Technical documents of the build-in expander SPCE652.100 are listed in the certificate EN-ST-000064).			



### **Enclosure 3**

**Sheet 1**

To Certificate No.: EN-ST-000060

Date : 10-06-2015

Instructions for the application of the approval component/system (see enclosure 1):

1. The device is suitable for use in intruder alarm systems according to EN 50131-1:2009.
2. The device complies with Environmental Class II of EN 50130-5:1998.