

BRE Certification Limited and LPCB

1719.02

Bucknalls Lane, Garston, Watford, Hertfordshire, WD25 9XX

Telephone: 01923 664100 Fax: 01923 664603 E-mail: enquiries@bre-certification.co.uk Web: www.bre-certification.co.uk

EC-CERTIFICATE OF CONFORMITY

0832 - CPD - 0006

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

55000-127 Series 65 conventional Class BR heat detector for use in fire detection and alarm systems

(For conditions of use for the product see the attached appendix)

placed on the market by

Apollo Fire Detectors Limited
36 Brookside Road, Havant, Hampshire PO9 1JR

and produced in the factory

Apollo Fire Detectors Limited
36 Brookside Road, Havant, Hampshire PO9 1JR

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan. The initial type-testing for the relevant characteristics of the product, the initial inspection and continuous surveillance of the factory and factory production control has been performed under the control of the approved body BRE Certification Limited.

This certificate attests that all provisions concerning the attestation of conformity (Level 1) and the performances described in Annex ZA of the standard(s)

EN 54 - 5: 2000 + A1: 2002 - Fire detection and fire alarm systems - Heat detectors - Point detectors

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on 4/9/2003 and remains valid as long as the product continues to be manufactured and the conditions laid down in the harmonised technical specification referenced or the manufacturing conditions in the factory or the FPC itself are not modified significantly and the required annual FPC assessments are maintained.



Richard Phillips
For and on behalf of BRE Certification Limited

Date of Issue: 23/2/2006
Issue Number: 3
Page: 1 of 3

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.
To check the authenticity of this certificate, please visit our website or contact us.

BRE Certification Limited and LPCB

Bucknalls Lane, Garston, Watford, Hertfordshire, WD25 9XX

Telephone: 01923 664100 Fax: 01923 664603 E-mail: enquiries@bre-certification.co.uk Web: www.bre-certification.co.uk

Appendix to EC Certificate of conformity 0832 - CPD - 0006

The details and conditions of use for the 55000-127 Series 65 conventional Class BR heat detector, placed on the market by Apollo Fire Detectors Limited are:

To be used in accordance with the suppliers installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings(*where applicable*):

Bases:

- 45681-200 Series 60 mounting base
- 45681-201 Series 60 diode mounting base
- 45681-245 Series 65 relay mounting base
- 45681-246 Series 65 auxillary mounting base
- 45681-247 Series 65 EOL 12 Volt mounting base
- 45681-248 Series 65 EOL 24 Volt mounting base



Richard Phillips
For and on behalf of BRE Certification Limited

Date of Issue: 23/2/2006
Issue Number: 3
Page: 2 of 3

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.
To check the authenticity of this certificate, please visit our website or contact us.

BRE Certification Limited and LPCB

Bucknalls Lane, Garston, Watford, Hertfordshire, WD25 9XX

Telephone: 01923 664100 Fax: 01923 664603 E-mail: enquiries@bre-certification.co.uk Web: www.bre-certification.co.uk

Appendix to EC Certificate of conformity 0832 - CPD - 0006

ALTERNATIVE MODEL NUMBERS AND LABELLING

Original Name	Alternative Name	Distributed by
55000-127	23900-K036-065	Kidde Fire Protection
55000-127	55000-127ADV	Advanced Electronics
55000-127	AL2401	Hagemeyer (UK) Ltd (Alto)
55000-127	BF302Z2H/C-TEC	C-TEC
55000-127	DT655	GE Security B.V (Aritech)
55000-127	F850677N	Chubb Fire Limited
55000-127	NL5718	Hagemeyer (UK) Ltd (Newlec)



Richard Phillips
For and on behalf of BRE Certification Limited

Date Of Issue: 23/2/2006
Issue Number: 3
Page: 3 of 3

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.
To check the authenticity of this certificate, please visit our website or contact us.